



**DEPARTMENT OF THE AIR FORCE
56TH FIGHTER WING (AETC)
LUKE AIR FORCE BASE AZ 85309-1629**

26 November 2024

MEMORANDUM FOR LUKE AFB MILITARY AND CIVILIAN PERSONNEL

FROM: 56 FW/CC

SUBJECT: Drinking Water System Service Line Inventory

1. IAW the Environmental Protection Agency's Lead and Copper Rule Revisions regulation (40 CFR 141.84), Luke AFB has completed its service line inventory. Luke partnered with Nicklaus Engineering, Inc. to complete the inventory. A combination of records review (real property records, utility master drawings, as-built drawings, and geographic information system data) and non-intrusive physical inspections (scratch and magnet tests) were used to identify service line material. As a result of the reviews and inspections, Luke has determined that it has no service lines that contain lead, galvanized service lines that require replacement, or service lines of unknown material.
2. For more information on Luke's service line inventory contact Mr. Kevin Haponek (kevin.haponek@us.af.mil). To learn more about Luke's drinking water sampling program, contact Bioenvironmental Engineering at 856-7521 (usaf.luke.56-mdg.mbx.56-omrs-sgxb@health.mil).

DAVID J. BERKLAND
Brigadier General, USAF
Commander